



CITY OF ATLANTA

FIRE DEPARTMENT

SHIRLEY FRANKLIN
MAYOR

City Hall East 675 Ponce de Leon Avenue, NE Suite 2001
Atlanta, GA 30308-1807
(404) 853-7093 * FAX (404) 853-7006

KELVIN J. COCHRAN
FIRE CHIEF

ICHIEFS ID – ATLFDHQ

APPLICATION FOR PERMIT TO ERECT A TENT FOR PUBLIC USE

EVENT: _____ DATE: _____ THROUGH _____

EVENT LOCATION _____

TOTAL NUMBER OF TENTS: _____ NUMBER OF TENT BY SIZE: 10x10 _____

10x20 _____ 15x15 _____ 20x20 _____ 30x30 _____ Other: Size(s) _____ # per Size _____

The tent/or air-supported structure shall be so located from any property line or permanent structure so as to be readily accessible by fire equipment.

An unobstructed passageway or fire road not less than 12 ft. wide and free from guy ropes or other obstructions shall be maintained on all sides of all tents or air-supported structures unless otherwise approved by the Fire Official.

Tents or air-supported structures and their appurtenances shall be adequately roped, braced, and anchored to withstand the elements of weather against collapsing.

Tents or air-supported structures shall be suitably treated to render them flameproof (Certificate required).

No shavings, sawdust or other similar combustibles shall be used on the floor.

THERE SHALL BE NO FLAMMABLE LIQUIDS ON THE PREMISES WITHOUT PRIOR APPROVAL FROM ATLANTA FIRE RESCUE

THE RULE AGAINST SMOKING SHALL BE RIGIDLY ENFORCED.

ALL WIRING SHALL BE DONE BY A LICENSED ELECTRICIAN.

EXIT FACILITIES SHALL COMPLY WITH THE FOLLOWING:

CAPACITY	MINIMUM NUMBER OF EXITS	MINIMUM WIDTH EACH EXIT(ft)	
		TENT	AIR-SUPPORTED STRUCTURES
UP TO 199	2	6	3
200 TO 499	3	6	6
500 TO 999	4	8	6
1000 TO 1999	5	10	8
2000 TO 2999	6	10	8
OVER 3000	7	10	8

PAGE TWO
TENT PERMIT

Exits shall be clearly marked.

Exits Shall Be Illuminated At All Times.

Exit Signs Shall Be Posted Clearly Indicating The Direction Of Travel.

2. One 2-A Type Extinguisher Shall Be Provided In Every Tent or Air- Supported Structure. One additional -A Type Extinguisher Shall Be Provided For Each Additional 3000 sq.ft. Maximum floor area per unit of A shall be 3,000 sq.ft. Maximum travel distance to Extinguisher shall be 75 feet.
3. A clearance of 3 feet shall be maintained around fire hydrants.

Applicant(s) Name: _____
Address: _____
City: _____
State: _____
Zip Code: _____
Telephone Number: _____

Property Owner(s) Name: _____
Address: _____
City: _____
State: _____
Zip Code: _____
Telephone Number: _____

Tent Rental Co. _____
Address: _____
City: _____
State: _____
Zip Code: _____
Telephone Number: _____

APPLICATION APPROVED: _____ APPLICATION DISAPPROVED: _____

BY: _____ DATE _____

ATLANTA FIRE RESCUE
FIRE SAFETY DIVISION

PLEASE CALL (404) 853-7802 FOR FINAL INSPECTION WHEN THE TENT IS ERECTED.

INSTALLATION APPROVED _____ DATE _____

BY: _____
NAME SIGNATURE

ATLANTA FIRE RESCUE, FIRE SAFETY DIVISION

TENT PERMIT FEE \$66.00 PAID:_____ DATE:_____ RECEIVED BY: _____

Make Check or Money Order Payable to the City of Atlanta